

ORDINANCE No. 1985

AN ORDINANCE ENACTED BY THE CITY COUNCIL OF THE CITY OF SALISBURY, MARYLAND TO REVISE THE WASTEWATER PRETREATMENT PROGRAM BASED ON THE RESULTS OF A LOCAL LIMITS STUDY.

WHEREAS, the City of Salisbury is required to perform a Local Limits Study as part of the City's National Pollution Discharge Elimination Study, which was reviewed and approved by the State of Maryland; and

WHEREAS, the Local Limits Study results determined that the Specific Pollutant Limitation of the maximum daily average of Total Lead of 0.69 mg/l listed in Section 13.12.070.E of the City Code needed to be changed to 0.20 mg/l and a new Specific Pollutant Limitation for Total Molybdenum need to be established with a maximum daily average of 0.54 mg/l.

NOW, THEREFORE, BE IT ENACTED AND ORDAINED by the Council of the City of Salisbury, Maryland, in regular session, that Section 13.12.070.E., Specific Pollutant Limitations, shall be amended as set forth below:

Section 13.12.070 E. Specific Pollutant Limitations. The following pollutant limits are established to protect against pass through and interference. No person shall cause to be discharged wastewater containing in excess of the following:

Pollutant	Concentration	Limitation
Five-day biochemical oxygen demand	350 mg/l	Maximum daily average
Total suspended solids	350 mg/l	Maximum daily average
Fats, oils and grease	150 mg/l	Instantaneous maximum
Total phosphorus	11 mg/l	Maximum daily average
Total mercury	0.001 mg/l	Maximum daily average
Total arsenic	0.24 mg/l	Maximum daily average
Total cadmium	0.69 mg/l	Maximum daily average
Total chromium	2.77 mg/l	Maximum daily average
Total copper	3.38 mg/l	Maximum daily average
Total cyanide	1.20 mg/l	Maximum daily average
Total lead	0.69 0.20 mg/l	Maximum daily average
Total molybdenum	0.54 mg/l	Maximum daily average
Total nickel	3.98 mg/l	Maximum daily average
Total silver	0.43 mg/l	Maximum daily average
Total zinc	2.61 mg/l	Maximum daily average

Limitations for other pollutants will be set in each industrial user's individual wastewater discharge permit as established by a technically based local limits study and approved by the engineer and Maryland Department of the Environment.

AND BE IT FURTHER ENACTED AND ORDAINED BY THE COUNCIL OF THE CITY OF SALISBURY, MARYLAND, the changes set forth in this Ordinance shall take effect upon final passage.

THIS ORDINANCE was introduced and read at a meeting of the Council of the City of Salisbury held on the ____ day of _____, 2006, and having been published as required by law, in the meantime, was finally passed at its meeting on the ____ day of _____, 2006.

ATTEST:

Brenda J. Colegrove
City Clerk

Michael P. Dunn
President of the City Council of the
City of Salisbury

Approved by me this _____ day of _____, 2006.

Barrie P. Tilghman

